

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES
Building 439
Santa Barbara, California 93106-1030
Telephone (805) 893-3356
Fax (805) 893-8592

SENT VIA: FAX ON THIS DATE
 HAND DELIVERY ON THIS DATE
 FEDERAL EXPRESS ON THIS DATE
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Santa Ynez Apartments 200's Refurbishment
Project No. FM120286L/293-99
Addendum No. 3


May 22, 2012

Enclosed is **ADDENDUM NO. 3** to the Construction Documents on the above-captioned project.

Bid date is May 29, 2012 at 2:30 PM to be held at:

CONTRACTING SERVICES
Facilities Management, Bldg. 439,
Door #E, Reception Counter
University of California, Santa Barbara
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.


Greg Moore
Associate Director, Contracting Services

ADDENDUM NUMBER NO. 3

To the
Construction Documents
Santa Ynez Apartments 200's Refurbishment

May 22, 2012

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as indicated: all other conditions shall remain the same.

I. ADVERTISEMENT FOR BIDS

Item No.

1. The Estimated Construction Cost for the subject project is hereby revised. Page 1, third paragraph REPLACE in its entirety with: Estimated Construction Cost \$1,580,000.00

II. DRAWINGS

Item No.

1. Sheets A-1, A-2, A-3, A-4, Key Notes. REPLACE Key Note 23 in its entirety with: 23. Restrictive window opening device. Install 3" offset from window center. Provide new at all first floor apartment sliding windows as indicated. Model "Zinic Twist Lock S4002" as manufactured by Glass Distributors Inc. or Equal.

Item No.

2. Sheet P-1, Equipment Schedule, TAG R/1. REVISE under Description/Specification to now indicate: Provided by Contractor.

Item No.

3. Sheet E-1, General Notes, ADD new note: 13. At project closeout furnish to the University extra material of lighting lamps in the quantity of 6 for each type and wattage of lamps used.

Item No.

4. Sheet E-1, Electrical Notes, ADD new last sentence to note 4: At project closeout furnish to the University extra material of 50 (fifty) CO/Smoke Detectors.

END OF ADDENDUM NO. 3