

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES
Building 439
Santa Barbara, California 93106-1030
Telephone (805) 893-3356
Fax (805) 893-8592

- SENT VIA:** FAX ON THIS DATE
 EMAIL (IF PROVIDED) ON THIS DATE
 FEDERAL EXPRESS ON THIS DATE
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

El Colegio Road Improvement Project – Phase 3
Project No. FM130100S/986051
Addendum No. 1


May 2, 2013

Enclosed is **ADDENDUM NO. 1** to the Construction Documents on the above-captioned project.

Bid Date: Thursday, May 9, 2013 at 2:30PM to be held at:

CONTRACTING SERVICES
Facilities Management, Bldg. 439
Door #E, Reception Counter
University of California, Santa Barbara
Santa Barbara, CA 93106-1030

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.



Greg Moore
Associate Director, Contracting Services

ADDENDUM NO. 1

to the

CONSTRUCTION DOCUMENTS

MAY 2, 2013

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

I. SPECIFICATIONS

Item No.

1-1

Section 01570 - "Traffic Control": "3.03 Road Closure Conditions":

Add the following paragraph:

"E. Contractor shall at minimum maintain one vehicle lane and one bike lane in each direction open at all times. Fire and emergency vehicles shall be allowed open access at all times unless otherwise approved by the University or County of Santa Barbara. Access into Isla Vista School and other adjacent properties shall be maintained open at all times, and also follow any additional requirements from the County in the encroachment permit. Contractor shall be responsible for providing manpower and facilities for implementing the approved traffic control devices."

1-2

Section 01080 - "Regulatory Requirements"; "1.03 Permits and Notifications":

Add the following paragraph:

"I. Encroachment Permit: Contractor shall obtain an encroachment permit from the County of Santa Barbara for work within the County right of way.

II. DRAWINGS

Item No.

2-1

DRAWING NO. E2 (SITE ELECTRICAL PLAN) through E4 (SITE ELECTRICAL PLAN); **Revise** Electrical Key Note #6 to read:

"Existing street lights and foundations to be removed by SCE, and SCE will patch existing sidewalk as necessary. Coordinate with SCE company to arrange removal as required by project schedule."

II. **DRAWINGS** (Continued)

Item No.

2-2

DRAWING NO. E2 (SITE ELECTRICAL PLAN) through E4 (SITE ELECTRICAL PLAN); **Revise** Electrical Key Note #12 to read:

"Set (N) street lighting splice box at location of removed street light, if required to repair existing street lighting circuits that will remain. SCE will repair and reconnect any existing street lighting circuits to remain. Splice box sizing shall be per SCE drawings. Coordinate this work with SCE."

END OF ADDENDUM NO. 1