

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES

Building 439
Santa Barbara, California 93106-1030
Telephone (805) 893-3356
Fax (805) 893-8592

- SENT VIA:** FAX ON THIS DATE
 HAND DELIVERY ON THIS DATE
 FEDERAL EXPRESS ON THIS DATE
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Ortega and Santa Catalina Dinning Commons
Boiler Replacement, Bldgs. 542 & 860
Project No. FM120316S/137-53/139-52
Addendum No. 3


April 24, 2012

Enclosed is **ADDENDUM NO. 3** to the Construction Documents on the above-captioned project.

Bid Date: Thursday, May 10, 2012 at 2:30 PM to be held at:

CONTRACTING SERVICES
Facilities Management, Bldg. 439
Door #E, Reception Counter
University of California, Santa Barbara
Santa Barbara, CA 93106-1030

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.



Greg Moore
Associate Director, Contracting Services

ADDENDUM NO. 3

to the

CONSTRUCTION DOCUMENTS

MAY 4, 2012

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

I. DRAWINGS - ORTEGA DINING COMMONS

Ortega Item No.

- 1-1. Drawing No. M-201: MECHANICAL BOILER ROOM DEMOLITION FLOOR PLAN. Change the demolition note called out on exhaust fan and ductwork from note #8 to note #10. Add the following demolition note #10.

"10. Remove exhaust fan, ductwork, grilles, supports, controls, electrical and all associated accessories."
- 1-2. Drawing No. M-100: MECHANICAL SCHEDULE, NOTES, LEGEND & ABBREVIATIONS: Insert the Blow Down Tank Schedule shown below.

BLOW DOWN TANK SCHEDULE												
MARK	MAKE	MODEL	BLOW DOWN CAPACITY (GALLONS)	INLET CONNECTION SIZE (INCHES)	OUTLET CONNECTION SIZE (INCHES)	DRAIN CONNECTION SIZE (INCHES)	VENT CONNECTION SIZE (INCHES)	MAX PRESSURE (PSI)	TANK DIAMETER (INCHES)	TANK HEIGHT WITH LEGS (INCHES)	WEIGHT (LBS)	REMARKS
BLOW DOWN TANK	PARKER OR EQUAL	BD2448	57	1-1/4	1-1/4	2	3	125	24	73	435	SEE NOTE 1
<u>Notes:</u> 1. Provide with drain cooling assembly.												

- 1-3. Drawing No. M-201: MECHANICAL BOILER ROOM FLOOR PLAN. Blow down tank is a Parker model BD 2448 or equal.

END OF ADDENDUM NO. 3