

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES
Building 439
Santa Barbara, California 93106-1030
Telephone (805) 893-3356
Fax (805) 893-8592

SENT VIA: FAX ON THIS DATE
 HAND DELIVERY ON THIS DATE
 FEDERAL EXPRESS ON THIS DATE
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Research Greenhouse
Project No. FM090158S/981530

Addendum No. 3

April 7, 2009

Enclosed is **ADDENDUM NO. 3** to the Construction Documents on the above-captioned project.

Bid date has been changed from 2:30PM on Friday, April 10, 2009 to **Friday, April 17, 2009 at 2:30PM** to be held at:

CONTRACTING SERVICES
Facilities Management, Bldg. 439,
Door #E, Reception Counter
University of California, Santa Barbara
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.



Anna Galanis
Director, Contracting Services

ADDENDUM NUMBER 3
to the
CONSTRUCTION DOCUMENTS
April 7, 2009

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

I. ADVERTISEMENT FOR BIDS

Item No.

1. First page, last sentence beginning with “Bid Deadline”, **Change** to read in it’s entirety:

“Bid Deadline: Sealed bids must be received on or before 2:30 P.M. on Friday, April 17, 2009. Sealed Bids will be received only at Contracting Services, Facilities Management, Building #439, Door #E, Reception Counter, University of California, Santa Barbara, Santa Barbara, California, 93106-1030.”

II SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

Item No.

1. Number 4, **Change** to read in it’s entirety:

“ Bids will be received on or before the Bid Deadline: 2:30 P.M., Friday, April 17, 2009 and only at: Contracting Services, Facilities Management, Building #439, Door #E, Reception Counter, University of California, Santa Barbara, Santa Barbara, California, 93106-1030.”

III. SPECIFICATIONS

Item No.

1. Section 13800, Greenhouse Environmental Control System, PART 1-GENERAL, 1.01 DESIGN INTENT, Para. 1.01.D **Change** last sentence to read in it's entirety:

“If some aspect of the system requirements listed herein cannot be met by the standard products of the control system manufacturer, the Contractor shall submit to the University, after Award, a list of said discrepancies and how the system manufacturer proposes to meet the requirement with an alternate capability, in accordance with Section 01640 - Product Options and Substitutions.”

Item No.

2. Section 13800, Greenhouse Environmental Control System, PART 2-PRODUCTS, 2.11 WIRING, Para. 2.11.B **Change** sentence to read in it's entirety:

“It is the responsibility of the Contractor to coordinate and direct the division of work between the Manufacturer and the Electrical Sub-Contractor so that all required conduits, wiring and accessories needed to accommodate both signal and power are in place and form a completely operational system.”

END OF ADDENDUM NO. 3