

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES  
Building 439  
Santa Barbara, California 93106-1030  
Telephone (805) 893-3356  
Fax (805) 893-8592

**SENT VIA:**  FAX ON THIS DATE  
 HAND DELIVERY ON THIS DATE  
 FEDERAL EXPRESS ON THIS DATE  
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Room 1410 Visitor Center Improvements  
Bren Hall Bldg. 521  
Project No. FM110119S/987763/077-63  
**Addendum No. 03**

January 3, 2011

Enclosed is **ADDENDUM NO. 03** to the Construction Documents on the above-captioned project.

Bid date has been changed from 2:30 PM on Tuesday January 4, 2011 to **Friday, January 7, 2011 at 2:30 PM** to be held at:

CONTRACTING SERVICES  
Facilities Management, Bldg. 439,  
Door #E, Reception Counter  
University of California, Santa Barbara  
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.

A handwritten signature in black ink, appearing to read 'Anna Galanis'.

Anna Galanis  
Director, Contracting Services

ADDENDUM NUMBER THREE

to the

CONSTRUCTION DOCUMENTS

January 3, 2011

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

I. Advertisement for Bids

Item No.

1. First page, last sentence beginning with “Bid Deadline...”, **CHANGE** to read in it’s entirety as follows:  
“Bid Deadline: Sealed bids must be received on or before **2:30 P.M. on Friday, January 7, 2011.** Sealed Bids will be received only at: Contracting Services, Facilities Management, Building #439, Door “E”, Reception Counter, University of California, Santa Barbara, Santa Barbara, California 93106-1030.”

II SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

Item No.

1. Number 4, **CHANGE** to read in it’s entirety as follows:  
“Bids will be received on or before the Bid Deadline: **2:30 P.M., Friday, January 7, 2011** and only at: Contracting Services, Facilities Management, Building #439, Door “E”, Reception Counter, University of California, Santa Barbara, Santa Barbara, California 93106-1030.”

### III SPECIFICATIONS

#### Item No.

1. Section 16750, Communications Cabling, Part 2 Materials, 2.03 Wire and Cable, C, **CHANGE** to read in its entirety:

“Fiber Innerduct: Fiber innerduct shall be provided from the main terminal to each sub terminal within the conduit routes identified. Innerduct shall have measured pull lines supplied by manufacturer, or inserted by Contractor during placement.  
Materials are: Carlon “Flex-Plus” non-metallic tubing, half inch (1/2”) diameter. Or equal.

  1. All innerduct shall be provided with male end adapters for future attachment into fiber panel boxes.  
Materials are: Carlon “Flex-Plus” non-metallic tubing yellow half inch (1/2”) diameter male adapters. Or equal.”

### IV. Drawings

#### Item No

1. Sheet E1.0 – General Notes, Symbols, Schedules & Details, Electrical Plan **CHANGE:**

“Change all Communications Cable from Cat 6 to Cat 5e.

#### Item No

2. Sheet E3.0 – Communications & Power Plans, Communication Plan and Enlarged Plan at Media Cabinet **CHANGE:**

“Change all Communications Cable from Cat 6 to Cat 5e.

END OF ADDENDUM NO. THREE