

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES  
Building 439  
Santa Barbara, California 93106-1030  
Telephone (805) 893-3356  
Fax (805) 893-8592

**SENT VIA:**  FAX ON THIS DATE  
 HAND DELIVERY ON THIS DATE  
 FEDERAL EXPRESS ON THIS DATE  
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Elevator Modernization – Francisco Torres, San Miguel  
Hall, San Rafael Hall  
Project No. FM070417L/988600  
**Addendum No. 4**

September 7, 2007

Enclosed is **ADDENDUM NO. 4** to the Construction Documents on the above-captioned project.

Bid date is **Monday, September 17, 2007 at 2:30 P.M.** to be held at:

CONTRACTING SERVICES  
Facilities Management, Bldg. 439,  
Door #E, Reception Counter  
University of California, Santa Barbara  
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.

A handwritten signature in black ink, appearing to read "Anna Galanis".

Anna Galanis  
Director, Contracting Services

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

ADDENDUM NUMBER 4

to the

Construction Documents  
September 7, 2007

GENERAL

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

I. SPECIFICATIONS

Item No.

1. Section 14221, MODERNIZATION OF ELEVATORS, Part 2 – PRODUCTS 2.01 A. San Miguel East & West, number 38. (Added in Addendum Two) **Change** to read as follows:  
"Remove and replace hoist ropes on Elevator # 1 and elevator #2." "Provide and install new hoistway and car doors at both the East and West Towers. Car doors finish to be stainless steel #4." "Hoistway doors to be provided and painted per UCSB color selection."  
"Clad aux. return panel and transom with new Stainless Steel #4." "Clad main return with new stainless steel #4."

END OF ADDENDUM NO. 4