

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES  
Building 439  
Santa Barbara, California 93106-1030  
Telephone (805) 893-3356  
Fax (805) 893-8592

**SENT VIA:**  FAX ON THIS DATE  
 HAND DELIVERY ON THIS DATE  
 FEDERAL EXPRESS ON THIS DATE  
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

Campus Hot Water Loop Project Phase I  
Project No. FM120340L/988880  
**Addendum No. 1**

April 5, 2012

Enclosed is **ADDENDUM NO. 1** to the Construction Documents on the above-captioned project.

Bid date is Tuesday, April 10, 2012 at 2:30 PM to be held at:

CONTRACTING SERVICES  
Facilities Management, Bldg. 439,  
Door #E, Reception Counter  
University of California, Santa Barbara  
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.

  
\_\_\_\_\_  
Greg Moore,  
Associate Director, Contracting Services

ADDENDUM NO. 1

to the

CONSTRUCTION DOCUMENTS

April 5, 2012

**GENERAL**

The following changes, additions or deletions shall be made to the following document(s) as Indicated; all other conditions shall remain the same.

**I. SPECIFICATIONS**

Item No.

1. Section 05120 – Structural Steel, Part 2 – Products, 2.3 Fabrication, E.: – **Add** in its entirety:
  1. All exposed steel supports including in Mechanical rooms, on roof, etc. shall be hot dipped galvanized.
  2. All structural steel frames for the exterior chases shall receive two rust inhibitive coats of primer.

Item No.

2. Section 02510 – Site Hot Water Distribution Systems, Part 2 – Products, 2.1 Materials, A.1.: – **Add** in its entirety:
  - a. Casings shall be SDR51.
  - b. All joints shall be insulated.

**II. DRAWINGS**

Item No.

3. Sheet M3, Campus Enlarged Heating Hot Water Piping Plan – 1: – **Add** note in its entirety:

“Provide trust block where pipe diameter is reduced.”

Item No.

4. Sheet M4, Campus Enlarged Heating Hot Water Piping Plan – 2: – **Add** note in its entirety:  
“Provide trust block where pipe diameter is reduced.”

Item No.

5. Sheet M12, Chemistry/Physical Sciences North (557/657) – Add Alt 1 – Heating Hot Water Piping Plan and Piping Elevations: – **Add** note in its entirety:  
“Provide trust block where pipe diameter is reduced.”

END OF ADDENDUM NO. 1