

UNIVERSITY OF CALIFORNIA, SANTA BARBARA

BERKELEY • DAVIS • IRVINE • LOS ANGELES • MERCED • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

OFFICE OF DESIGN & CONSTRUCTION SERVICES and PHYSICAL FACILITIES

CONTRACTING SERVICES
Building 439
Santa Barbara, California 93106-1030
Telephone (805) 893-3356
Fax (805) 893-8592

SENT VIA: FAX ON THIS DATE
 HAND DELIVERY ON THIS DATE
 FEDERAL EXPRESS ON THIS DATE
 UNITED PARCEL SERVICE ON THIS DATE

HOLDERS OF PLANS AND SPECIFICATIONS:

HSSB Tower and Arcade PVC Roof Replacement, HSSB
Building 515
Project No. FM110029S/980835
Addendum No. ONE

September 1, 2010

Enclosed is **ADDENDUM NO. ONE** to the Construction Documents on the above-captioned project.

Bid date has been changed from Tuesday, September 7, 2010 at 2:30 P.M. to **Friday, September 10, 2010 at 2:30 P.M.** to be held at:

CONTRACTING SERVICES
Facilities Management, Bldg. 439,
Door #E, Reception Counter
University of California, Santa Barbara
Santa Barbara, CA 93106-1030.

Late arrivals shall be disqualified. Please allow time for unforeseen traffic delays, securing a parking permit and potential parking problems.

A handwritten signature in black ink, appearing to read 'Anna Galanis'.

Anna Galanis
Director, Contracting Services

ADDENDUM NUMBER ONE
To the
CONSTRUCTION DOCUMENTS

September 1, 2010

The following changes, additions or deletions shall be made to the following document(s) as indicated; all other conditions shall remain the same.

I. ADVERTISEMENT FOR BIDS

Item No

1. Second Page, first paragraph, **CHANGE** to read in it's entirety as follows:
"Bid Deadline: Sealed bids must be received on or before 2:30 P.M. on Friday, September 10, 2010. Sealed Bids will be received only at: Contracting Services, Facilities Management, Building #439, Door E, Reception Counter, University of California, Santa Barbara, Santa Barbara, California 93106-1030."

II. SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

Item No

1. Number 4, **CHANGE** to read in it's entirety as follows:
"Bids will be received on or before the Bid Deadline: 2:30 P.M. on Friday, September 10, 2010 and only at: Contracting Services, Facilities Management, Building #439, Door E, Reception Counter, University of California, Santa Barbara, Santa Barbara, California 93106-1030."

III. SPECIFICATIONS

Item No

1. SECTION 07545 – THERMOPLASTIC MEMBRANE ROOFING “, Part 1, “General”, 1.12 Regulatory Requirements”; “C” .. **DELETE** “C” in it's entirety.

Item No

2. SECTION 07545 – THERMOPLASTIC MEMBRANE ROOFING , Part 1, “General”, “1.16 Warranty”, “A.1”, **CHANGE** to read in it's entirety as follows:
“A. 1. Minimum twenty (20) year NDL manufacturers warranty on the membrane and fifteen (15) years on the color degradation. Refer to Section 01740, Guarantees, Warranties, Bonds, Service and Maintenance Contracts, for submittal form.”

Item No

3. SECTION 07545 – THERMOPLASTIC MEMBRANE ROOFING , Part 1, “General”, “1.16 Warranty”, “A.2”, **CHANGE** to read in it's entirety as follows:
“A. 2. Two (2) year Roofing Contractor Warranty. Refer to Section 01740, Guarantees, Warranties, Bonds, Service and Maintenance Contracts, for submittal form.” ”

Item No

4. SECTION 07545 – PVC THERMOPLASTIC MEMBRANE ROOFING; Part 2, “Products” “2.02, “Materials”, “4”, , REPLACE in it’s entirety with the following:
“ 4. Main Field Sheet- 60 mils thermoplastic membrane minimum. Color to match roof as close as possible and be from the manufacturers standard palette.”

Item No

5. SECTION 07545 – PVC THERMOPLASTIC MEMBRANE ROOFING; Part 2, “Products” “2.03 Flashing Materials”, **ADD** “C” to read in it’s entirety as follows:
“C. All new flashing materials to b e 24 galvanized versus 24 GA 316L S.S. as indicated on all sheets with post-fabrication Kynar finish with a standard color palette to match as close as possible to the PVC colored membrane.”

Item No

6. SECTION 07545 – PVC THERMOPLASTIC MEMBRANE ROOFING; Part 2, “Products” “2.07 Insulation/ Overlayment”, “B”, **CHANGE** to read in it’s entirety as follows:
“B. Dens Deck Prime, or equal.

END OF ADDENDUM NO. 1